

(A) Technical Qualification requirement:

1. Agencies having registration with GETCO/State Govt./ Central Govt./ Railway/ Semi Govt. in E2 or above class.
2. Bidder shall have experience for similar type of jobs/ nature of work or shall have experience to work in live switchyard.
3. Latest bank solvency certificate from any nationalized bank of a sum of 20% of the estimated cost of each tender amount.(Not more than one year old)
4. Certified copy of Provident fund code number shall be submitted.
5. Bidder shall have to provide all required tools and tackles to meet with the subject job work.
6. Bidder shall have to submit PAN Card.
7. Bidder shall have to submit service tax registration.
8. Bidder shall have to submit partnership deed/ company registration.
9. All registered agencies with GETCO for civil and electrical associated works shall be considered as eligible for participating in the tender for the subject work.
10. All present agencies who have been awarded 66KV & EHV substations for O&M works shall also be considered as eligible for participating in the tender for the subject work.

(B) Special condition of contract to be added in present tender condition: -

1. Work shall not be started without work permit.
2. Work permit will be given to the authorized electrical supervisor of the agency.
3. Electrical Supervisor must have minimum qualification of Diploma Electrical/ITI Technician/2nd class wireman/ wireman.
4. Electrical supervisor with working experience of live switchyard of substations is preferable.
5. Tools & Tackles which are to be used should not come in the induction-zone in live switchyard. Moreover tools and tackles handles are preferably non-conductive type.
6. Excavated grass has to be removed on daily basis from GETCO premises.
7. Vehicle will be allowed up to approach road only as per instruction of Engineer in Charge.
8. Agency is excluded from doing any work related to electrical equipment/installation, none of their workers will even touch such equipments
9. The height of the vehicle shall not be more than 3 mtrs, while it is loaded with grass.
10. Chemical use for Anti-weed shall be approved by concerned Executive Engineer in writing before purchasing and execution of work.
11. Electrical supply and water will be provided by GETCO at free of cost for anti-weed treatment only.
12. To meet with statutory requirement, if any license is required for purchase or handling of chemical use for anti weeding treatment, the contractor/ agency shall have to be followed the rules and regulations.
13. Contractor shall have to keep all precautionary measures at site required for handling of chemicals use in anti weeding treatment.
14. Any injury / accident to manpower of agency / contractor during anti weeding treatment required medical treatment shall be provided by the contractor on his own risk & cost.

15. Terms and conditions regarding Industrial laws minimum wages act PF and other statutory rules to be followed strictly.
16. Labour laws are to be followed strictly – labour registration workmen compensation.
17. GETCO's safety policy to be implemented strictly
18. JCB's and tractor shall not be allowed to remove the grass in live switchyard.
19. Contractor shall have to give all required medical treatment due to snake bite / insect bite to any manpower of agency.
20. Children are not allowed in live switchyard.
21. Labour camps shall not be allowed within GETCO premises.
22. Cattles shall not be allowed in GETCO premises.
23. Agency shall have to provide proof of labour/supervisor payment and PF record, along with bill.